

# ENVIRONMENTAL PRODUCT DECLARATION

as per ISO 14025 and EN 15804+A2

Owner of the Declaration	NMC S.A.
Programme holder	Institut Bauen und Umwelt e.V. (IBU)
Publisher	Institut Bauen und Umwelt e.V. (IBU)
Declaration number	EPD-NMC-20220225-IBD1-EN
Issue date	13.09.2022
Valid to	12.09.2027

CLIMAFLEX® naturefoam exzentro  
NMC S.A.

[www.ibu-epd.com](http://www.ibu-epd.com) | <https://epd-online.com>



CLIMAFLEX®

naturefoam  
exzentro

ECO PLATFORM  
**EPD**  
VERIFIED



EXCENTRIC PIPE INSULATION,  
MADE OF RENEWABLE AND  
RECYCLED RAW MATERIALS.

nmc

TECHNICAL  
INSULATION

## 1. General Information

### NMC S.A.

#### Programme holder

IBU – Institut Bauen und Umwelt e.V.  
Hegelplatz 1  
10117 Berlin  
Germany

#### Declaration number

EPD-NMC-20220225-IBD1-EN

#### This declaration is based on the product category rules:

Insulating materials made of foam plastics, 01.2019  
(PCR checked and approved by the SVR)

#### Issue date

13.09.2022

#### Valid to

12.09.2027



Dipl. Ing. Hans Peters  
(chairman of Institut Bauen und Umwelt e.V.)



Dr. Alexander Röder  
(Managing Director Institut Bauen und Umwelt e.V.)

### CLIMAFLEX® naturefoam exzentro

#### Owner of the declaration

NMC S.A.  
Gert-Noël Strasse  
BE-4731 Eynatten

#### Declared product / declared unit

CLIMAFLEX® naturefoam exzentro

#### Scope:

Product line CLIMAFLEX® naturefoam exzentro  
Thermal insulation products for building equipment and industrial insulations made of Polythene-based, closed-cell foam pipe insulation with a robust protective coating (PEF) according to EN14313. This declaration is an Environmental Product Declaration according to ISO14025 describing the specific environmental performance of the product produced in Belgium at the site of Eynatten.

The owner of the declaration shall be liable for the underlying information and evidence; the IBU shall not be liable with respect to manufacturer information, life cycle assessment data and evidences.

The EPD was created according to the specifications of EN 15804+A2. In the following, the standard will be simplified as EN 15804.

#### Verification

The standard EN 15804 serves as the core PCR

Independent verification of the declaration and data  
according to ISO 14025:2011

internally  externally



Vito D'Incognito  
(Independent verifier)

## 2. Product

### 2.1 Product description/Product definition

CLIMAFLEX® naturefoam exzentro is the Professional Polyethylene-based closed-cell foam pipe insulation with a robust PE protective coating, containing recycled PE, for continuous energy saving and condensation control purposes. CLIMAFLEX® naturefoam exzentro with its rectangular and thin design, it is used in flooring. For the placing on the market of the product in the European Union/European Free Trade Association (EU/EFTA) (with the exception of Switzerland) - Thermal Insulation products for building equipment and industrial installations cf. PCR. Factory-made polyethylene foam (PEF) and the CE-marking. For the application and use, the respective national provisions apply.

### 2.2 Application

CLIMAFLEX® naturefoam exzentro is used to insulate pipes for heating and plumbing.

- Polyethylene foam is a cost-efficient material with good insulating properties.

- Products made of PE foam, containing recycled PE, yield an excellent cost/performance ratio.
- Heat loss control and noise reduction in fresh- and waste water and heating system

### 2.3 Technical Data

#### Constructional data

Performance data of the product in accordance with the Declaration of Performance with respect to its Essential Characteristics according to EN 14313 apply. Further data:

Name	Value	Unit
Gross density	34.3	kg/m <sup>3</sup>
Thermal conductivity	0.04 - 0.042	W/(mK)
Reaction To Fire Acc.to EN 13501-1 depending on the	E	

thickness		
Max Service Temperature Acc. To EN 14707	100	°C
Min Service Temperature	0	°C
water absorption Acc. to EN 13472	WS005	-
traces quantities of water-soluble ions and pH-value Acc. to EN 13468	Cl < 20 – F < 4 - pH 5,8	-

## 2.4 Delivery status

The PE products are supplied as tubes. The tubes are delivered in lengths of 2 m packed in cardboard boxes. The insulating sleeves in the CLIMAFLEX® naturefoam exzentro have a thickness ranging from 9 to 51mm and an inside diameter ranging from 15 to 42mm. These products are categorized according to thermal conductivity (Lambda\*). The category of product with lambda 0,040 (W/(mK)) (acc. to EN ISO 8497 and EN 12667) includes CLIMAFLEX® naturefoam exzentro with thickness 9 mm, while the category of product with lambda 0,042 (W/(mK)) (acc. to EN 12667) includes CLIMAFLEX® naturefoam exzentro with thicknesses from 25 to 51mm products.

## 2.5 Base materials/Ancillary materials

### Base materials

CLIMAFLEX® naturefoam exzentro is a flexible insulation material based on Polyethylene with a protecting coating of PE., which consists of around seven basic components. The following table displays the different elements of formula.

This product contains substances listed in the candidate list (date: 08.07.2021) exceeding 0.1 percentage by mass: **No**.

This product contains other carcinogenic, mutagenic, reprotoxic (CMR) substances in categories 1A or 1B which are not on the candidate list, exceeding 0.1 percentage by mass: **No**.

Biocide products were added to this construction product or it has been treated with biocide products (this then concerns a treated product as defined by the (EU) Ordinance on Biocide Products No. 528/2012): **No**.

Name	Value	Unit
LDPE	40.40	%
Flame retardant	3.2	%
LLDPE	2.65	%
Pigment	3.15	%
Internally recycled PE	43.20	%
Volume stabilizer	1.3	%
Blowing Agent	6.10	%

PE and fillers give the aspect of the product. The blowing agent causes the expansion during manufacturing. And the flame retardants ensure the fire resistance. According the European Chemicals Regulation REACH Manufacturers, importers and downstream users must register their chemicals and are responsible for their safe use on their own. For its production NMC S.A. uses exclusively verifiably registered and approved substances. Products manufactured and put on the market by NMC need to be registered. CLIMAFLEX® naturefoam exzentro does not contain Substances of Very High Concern (SVHC). Antimony trioxide and halogenated flame retardants are applied.

## 2.6 Manufacture

The manufacturing process consists of a continuous extrusion. Solid pellets of thermoplastic resin are fed to a melting zone in which the resin is melted, to form a flowable thermoplastic mass. The thermoplastic mass is then metered to a mixing zone where the thermoplastic mass is thoroughly mixed with a blowing agent under pressure. The mixture of thermoplastic resin and blowing agent is then forced through a die, which imparts a shape to the thermoplastic mass, into a zone of lower pressure, such as atmospheric pressure. The blowing agent expands to form the cells of the foam and the thermoplastic foam is cooled through an inline water cooler. The protection coating "skin" is applied by co-extrusion. The "skin" is made with solid pellets of thermoplastic resin and some additives, which is, with the help of an extruder, applied around the foam. There is not a foaming agent used in this case. The die is positioned around the "naked" foam and deposes a small thickness ( $\pm 0.1$  mm) of PE film on the foam. At the end of this process the profiles are cut at dimension. Quality assurance : The manufacture is certified ISO 9001 for the quality management. The product corresponds to the product standard EN 14313 and has a Declaration of Performance according to the DOP no. W1PEF300 ; W1PEF400 (see [www.nmc-insulation.com](http://www.nmc-insulation.com))

## 2.7 Environment and health during manufacturing

During all manufacturing steps of NMC S.A. Belgium, the production follows the national guidelines and regulations. Solar panels are installed on the roof of the warehouses.

## 2.8 Product processing/Installation

CLIMAFLEX® naturefoam exzentro can be installed using basic tools like knives. No special tools, or specific protection is necessary. When applying adhesives the information given in the relevant safety data sheets is to be heeded. The recommendations on how to use the product are described in the application manuals or video's. More details are listed on the Web Page [www.nmc-insulation.com](http://www.nmc-insulation.com)

## 2.9 Packaging

CLIMAFLEX® naturefoam exzentro products are packed in cardboard boxes and transported on reusable pallets. The packaging material can be recycled. The pallets used to transport the products are taken back or exchanged when the CLIMAFLEX® naturefoam exzentro is delivered, so the use of pallets is a close loop economy.

## 2.10 Condition of use

During the use of the product for the purpose for which they are intended, there are no modifications to the product during the use, except if due to extraordinary impact (see point 2.13).

## 2.11 Environment and health during use

There are no particular aspects of the material composition during the use. CLIMAFLEX® naturefoam exzentro products are used in a wide range and variety of applications for which the product is intended. The PEF foams fulfil the German, Belgian and French regulations regarding the emission of VOC with emissions far below the most severe limit values. The

Eurofin Product Testing institute, on the demand of the CEFEP (European group of PEF and FEF 4 Environmental Product Declaration NMC sa – CLIMAFLEX® naturefoam exzentro manufacturers) has made a wide range of tests for different PEF products from different manufacturers. The insulation of heating pipes with CLIMAFLEX® naturefoam exzentro allows a drastic reduction of CO<sub>2</sub> emission during the full service life of the installation. The quantification of this is not in the topic of this EPD, and has to be evaluated in the frame of the LCA from the complete installation

## 2.12 Reference service life

The function of CLIMAFLEX® naturefoam exzentro is to ensure the insulation of heating and sanitary installations for a reference service life (RSL) of 50 years. This duration is based on the frequency of replacement of sanitary and heating piping in buildings. Although the insulation products are still effective after 50 years, it is assumed that when replacing the piping, the insulation is not reused and is disposed of with the piping. 50 years is the minimum Reference Service Life recommended in EN16783.

## 2.13 Extraordinary effects

### Fire

Fire According to CLIMAFLEX® naturefoam exzentro are classified as EURO CLASS E and therefore have a limited speed of inflammation.

### Fire protection

Name	Value
------	-------

## 3. LCA: Calculation rules

### 3.1 Declared Unit

The declaration refers to 1 m<sup>3</sup> of produced insulation product. For the LCA calculations, as the product is foam and have some tolerances, the density declared is the average between the product categories. The thermal conductivity coefficient (Lambda-value) and R-value per 25 mm thickness per product brand is provided below as additional information and support for installers.

#### Declared unit

Name	Value	Unit
Gross density	34.3	kg/m <sup>3</sup>
Declared unit	1	m <sup>3</sup>
Conversion factor from 1 m <sup>3</sup> to 1 linear meter	Value for 1 m divided section of the insulation pipe (m <sup>2</sup> )	m
Gross Density volume for 1 kg	0.02116	m <sup>3</sup>
Thermal Conductivity at 40°C	0.040 - 0.042	W/(mK)

Thermal Conductivity  $\lambda$ : 0.040 W/mK at (40°C) R-value- thickness: 9 mm: +/- 3.5 (m<sup>2</sup>K)/W Thermal Conductivity  $\lambda$ : 0.042 W/mK at (40°C) R-value- thickness: 25 mm: +/- 3,355 (m<sup>2</sup>K)/W depending on the pipe diameter.

Building material class	E
-------------------------	---

### Water

CLIMAFLEX® naturefoam exzentro are closed cell foam and obtain the better water absorption class WS005 according to the product standard

### Mechanical destruction

CLIMAFLEX® naturefoam exzentro are flexible foam covered with a PE protective coating CLIMAFLEX® naturefoam exzentro are not UV resistant. The use is not recommended for outside applications without complementary UV protection

### 2.14 Re-use phase

In principle, if removed carefully, CLIMAFLEX® naturefoam exzentro can be reused on any other piping system of similar dimensions. Any material not suitable for reuse is fully recyclable.

### 2.15 Disposal

CLIMAFLEX® naturefoam exzentro are fully recyclable using the same recycling systems as those used for other forms of PE waste. Any non-recycled material should be disposed of the materials according to the local regulations, and by the *European Waste Catalogue* waste code 07 02 13 waste Plastic "Low Density Polyethylene"

### 2.16 Further information

Additional information about CLIMAFLEX® naturefoam exzentro can be found on the NMC web site [www.nmc-insulation.com](http://www.nmc-insulation.com). Here specification clauses, data sheets and application manuals can be found.

### 3.2 System boundary

The Data collection refers to the yearly production in 2021

#### Module A1 to A3:

The LCA calculation covers the production of the raw materials, transport of these to the plant, the mixing of raw materials according to the respective recipes, manufacturing of the foam product and packaging for dispatch. All production takes place exclusively in Eynatten, Belgium.

#### Module A4:

The type of transport included in the LCA model is a truck mix Euro Cargo 0-6 with diesel fuel. As the product is foam with a comparatively low density, the product volume is the limiting factor on loading. CLIMAFLEX® naturefoam exzentro is rarely the only product loaded in trucks, they are usually grouped with other products of higher density according to the place of destination. In addition, NMC s.a. works with regional expeditions companies that group different goods in order to optimize the weight-to-volumes ratio. For this reason, the fill rate of the trucks has been set to 10% of the mass payload capacity.

#### Module A5:

The LCA calculation covers the production of the raw materials, transport of these to the plant, the mixing of raw materials according to the respective recipes, manufacturing of the foam product and packaging for dispatch. All production takes place exclusively in Eynatten, Belgium.

#### Module B1-B7:

The foam insulation products do not require maintenance, replacement or refurbishment while in use. The information modules B1 – B7 are not declared. Although the insulation of the piping naturefoam exzentro contributes to a significant reduction of CO<sub>2</sub> emissions from the heating or cooling equipment, this is not taken into account in this LCA. It should, however, be taken into account in the calculation of the environmental impacts of the complete heating and cooling systems or of the complete building

#### Module C1:

As for the installation of the product, the disassembly is done manually and does not require any specific equipment. Disassembly is generally carried out at the same time as the replacement or removal of sanitary pipes. Consequently, there are no impacts associated with C1.

#### Module C2:

Transport at the end-of-life stage is modelled as a Euro Cargo 0-6 mix truck with diesel fuel. The average distance to either mechanical recycling is assumed to be 100 km.

#### Module C3:

The scenario that has been retained for this Life Cycle Assessment is the 100% recycling

#### Module C4:

As CLIMAFLEX® naturefoam exzentro is fully recyclable, the legislation is pushing more in this direction and the overall pressure on plastic recycling is growing, therefore the scenario with 100% recycling is considered.

#### Module D:

The end-of-life scenarios for packaging material and product do not deliver any benefits for the next system. The recycling of cardboard is a closed cycle with the production process. The CLIMAFLEX® naturefoam exzentro foam is fully recyclable and can be used as a direct one-for-one substitute for virgin PE-LD granulates, with only minor additive additions.

### 3.3 Estimates and assumptions

The LCA calculation is conducted using the *Gabi ts* - database. Not all necessary LCIs are included in the database. Where data were missing or were unavailable or where suppliers were unable to provide complete information, proxy datasets have been used. The environmental burden for the production of pigments, flame retardants and volume stabilizers are approximated.

### 3.4 Cut-off criteria

Any glue and adhesive tapes used during the installation (A5) have not been included as quantification of these materials is uncertain and their

use by the various installers is too diverse, adhesives and glues are not required in all/most cases, but may be used for some applications. In this study no others cut-off criteria have been applied and all elementary incoming processes as well as all energy and water inputs and waste outputs have been counted.

### 3.5 Background data

The software system for life cycle engineering *GaBi 2021 life cycle database used in the GaBi 10 software environment (Service Pack 2021001000)* developed by Thinkstep AG was used to perform this LCA.

### 3.6 Data quality

All the foreground data requiring such energy or raw material coming from production were verified and cross-checked before being included in the model. Most of the life cycle inventories for the basic materials are contained in the *GaBi 10 software*. For electrical and thermal energy Belgium-specific grid mixes and Belgium-specific supply for natural gas were considered.

### 3.7 Period under review

The production data for the year 2021 were used for the realization of this study

### 3.8 Allocation

There is no co-product or by-product generated during the production of NMC's products. Due to the lack of specific data per production line and product, the energy has been allocated per overall produced volume of insulation foam.

#### Production waste

Most of the production waste from the process (machine start, end of production, non-conforming products, etc.) is recycled internally in order to be reused in the manufacturing process. These impacts are accounted for in A1-A3.

#### Installation and End-of-Life waste

Installation of the foam products is done by hand and requires no special equipment apart from a knife. Installation off-cut is not considered in this calculations. Any glue and adhesive tapes used during the installation phase were not included in the LCA

### 3.9 Comparability

Basically, a comparison or an evaluation of EPD data is only possible if all the data sets to be compared were created according to *EN 15804* and the building context, respectively the product-specific characteristics of performance, are taken into account.

## 4. LCA: Scenarios and additional technical information

### Characteristic product properties

#### Information on biogenic Carbon

#### Information on describing the biogenic Carbon Content at factory gate

Name	Value	Unit
Biogenic carbon content in product	0	kg C
Biogenic carbon content in accompanying packaging	5.08	kg C

#### Transport to the building site (A4)

Name	Value	Unit
Litres of fuel	0.069	l/100km
Transport distance	453	km
Capacity utilisation (including empty runs)	10	%
Gross density of products transported	34.3	kg/m <sup>3</sup>

**Reference service life**

Name	Value	Unit
Reference service life	50	a

**End of life (C1-C4)**

Name	Value	Unit
Recycling	34.3	kg

## 5. LCA: Results

### DESCRIPTION OF THE SYSTEM BOUNDARY (X = INCLUDED IN LCA; ND = MODULE OR INDICATOR NOT DECLARED; MNR = MODULE NOT RELEVANT)

PRODUCT STAGE		CONSTRUCTION PROCESS STAGE	USE STAGE							END OF LIFE STAGE				BENEFITS AND LOADS BEYOND THE SYSTEM BOUNDARIES		
Raw material supply	Transport	Manufacturing	Transport from the gate to the site	Assembly	Use	Maintenance	Repair	Replacement	Refurbishment	Operational energy use	Operational water use	De-construction demolition	Transport	Waste processing	Disposal	Reuse-Recovery-Recycling-potential
A1	A2	A3	A4	A5	B1	B2	B3	B4	B5	B6	B7	C1	C2	C3	C4	D
X	X	X	X	X	ND	ND	MNR	MNR	MNR	ND	ND	ND	X	X	X	X

### RESULTS OF THE LCA - ENVIRONMENTAL IMPACT according to EN 15804+A2: 1 m<sup>3</sup> CLIMAFLEX® naturefoam exzentro

Core Indicator	Unit	A1-A3	A4	A5	C2	C3	C4	D
GWP-total	[kg CO <sub>2</sub> -Eq.]	97.39	1.64	0.00	0.29	3.69	0.00	-85.12
GWP-fossil	[kg CO <sub>2</sub> -Eq.]	97.93	1.65	0.00	0.29	3.64	0.00	-84.39
GWP-biogenic	[kg CO <sub>2</sub> -Eq.]	-0.78	-0.02	0.00	0.00	0.05	0.00	-0.72
GWP-luluc	[kg CO <sub>2</sub> -Eq.]	0.25	0.01	0.00	0.00	0.00	0.00	-0.01
ODP	[kg CFC11-Eq.]	7.10E-8	1.62E-13	0.00E+0	2.82E-14	1.51E-10	0.00E+0	-5.17E-10
AP	[mol H <sup>+</sup> -Eq.]	3.52E-1	1.95E-3	0.00E+0	3.40E-4	5.22E-3	0.00E+0	-1.17E-1
EP-freshwater	[kg P-Eq.]	5.05E-4	5.90E-6	0.00E+0	1.03E-6	2.44E-5	0.00E+0	-1.58E-4
EP-marine	[kg N-Eq.]	5.13E-2	6.52E-4	0.00E+0	1.13E-4	2.08E-3	0.00E+0	-3.43E-2
EP-terrestrial	[mol N-Eq.]	5.40E-1	7.75E-3	0.00E+0	1.35E-3	2.11E-2	0.00E+0	-3.57E-1
POCP	[kg NMVOC-Eq.]	1.96E-1	1.97E-3	0.00E+0	3.43E-4	5.04E-3	0.00E+0	-1.12E-1
ADPE	[kg Sb-Eq.]	2.81E-1	1.66E-7	0.00E+0	2.89E-8	2.12E-6	0.00E+0	-2.15E-5
ADPF	[MJ]	3.00E+3	2.17E+1	0.00E+0	3.77E+0	1.09E+2	0.00E+0	-3.25E+3
WDP	[m <sup>3</sup> world-Eq deprived]	6.83E+0	1.85E-2	0.00E+0	3.21E-3	2.63E-1	0.00E+0	-1.44E+0

Caption GWP = Global warming potential; ODP = Depletion potential of the stratospheric ozone layer; AP = Acidification potential of land and water; EP = Eutrophication potential; POCP = Formation potential of tropospheric ozone photochemical oxidants; ADPE = Abiotic depletion potential for non-fossil resources; ADPF = Abiotic depletion potential for fossil resources; WDP = Water (user) deprivation potential

### RESULTS OF THE LCA - INDICATORS TO DESCRIBE RESOURCE USE according to EN 15804+A2: 1 m<sup>3</sup> CLIMAFLEX® naturefoam exzentro

Indicator	Unit	A1-A3	A4	A5	C2	C3	C4	D
PERE	[MJ]	494.43	1.50	0.00	0.26	67.38	0.00	-243.67
PERM	[MJ]	0.00	ND	ND	ND	ND	ND	ND
PERT	[MJ]	494.43	1.50	0.00	0.26	67.38	0.00	-243.67
PENRE	[MJ]	1201.11	21.76	0.00	3.79	109.37	0.00	-3256.17
PENRM	[MJ]	1821.58	ND	ND	ND	ND	ND	ND
PENRT	[MJ]	3022.69	21.76	0.00	3.79	109.37	0.00	-3256.17
SM	[kg]	12.65	ND	ND	ND	ND	ND	ND
RSF	[MJ]	0.00	ND	ND	ND	ND	ND	ND
NRSF	[MJ]	0.00	ND	ND	ND	ND	ND	ND
FW	[m <sup>3</sup> ]	0.55	0.00	0.00	0.03	0.00	0.00	-0.39

Caption PERE = Use of renewable primary energy excluding renewable primary energy resources used as raw materials; PERM = Use of renewable primary energy resources used as raw materials; PERT = Total use of renewable primary energy resources; PENRE = Use of non-renewable primary energy excluding non-renewable primary energy resources used as raw materials; PENRM = Use of non-renewable primary energy resources used as raw materials; PENRT = Total use of non-renewable primary energy resources; SM = Use of secondary material; RSF = Use of renewable secondary fuels; NRSF = Use of non-renewable secondary fuels; FW = Use of net fresh water

### RESULTS OF THE LCA – WASTE CATEGORIES AND OUTPUT FLOWS according to EN 15804+A2: 1 m<sup>3</sup> CLIMAFLEX® naturefoam exzentro

Indicator	Unit	A1-A3	A4	A5	C2	C3	C4	D
HWD	[kg]	7.83E-4	1.15E-10	0.00E+0	2.00E-11	1.16E-8	0.00E+0	-3.04E-7
NHWD	[kg]	4.03E+0	3.54E-3	0.00E+0	6.17E-4	1.45E-1	0.00E+0	-8.99E-1
RWD	[kg]	1.30E-1	4.04E-5	0.00E+0	7.03E-6	2.54E-2	0.00E+0	-2.72E-2
CRU	[kg]	ND	ND	ND	ND	ND	ND	ND
MFR	[kg]	ND	ND	12.65	ND	47.26	ND	ND
MER	[kg]	ND	ND	ND	ND	ND	ND	ND
EEE	[MJ]	ND	ND	ND	ND	ND	ND	ND
EET	[MJ]	ND	ND	ND	ND	ND	ND	ND

Caption HWD = Hazardous waste disposed; NHWD = Non-hazardous waste disposed; RWD = Radioactive waste disposed; CRU = Components for re-use; MFR = Materials for recycling; MER = Materials for energy recovery; EEE = Exported electrical energy; EET = Exported thermal energy

### RESULTS OF THE LCA – additional impact categories according to EN 15804+A2-optional: 1 m<sup>3</sup> CLIMAFLEX® naturefoam exzentro

Indicator	Unit	A1-A3	A4	A5	C2	C3	C4	D
PM	[Disease Incidence]	1.72E-5	1.50E-8	0.00E+0	2.60E-9	4.16E-8	0.00E+0	-8.81E-7
IRP	[kBq U235-Eq]	1.09E+1	6.10E-3	0.00E+0	1.06E-3	1.77E+0	0.00E+0	-2.69E+0
ETP-fw	[CTUe]	1.64E+3	1.54E+1	0.00E+0	2.67E+0	4.25E+1	0.00E+0	-1.55E+3
HTP-c	[CTUh]	4.27E-8	3.17E-10	0.00E+0	5.51E-11	1.05E-9	0.00E+0	-3.81E-8
HTP-nc	[CTUh]	3.34E-6	1.74E-8	0.00E+0	3.02E-9	3.25E-8	0.00E+0	-1.77E-6
SQP	[·]	3.01E+2	9.17E+0	0.00E+0	1.60E+0	6.87E+1	0.00E+0	-1.66E+2

Caption PM = Potential incidence of disease due to PM emissions; IR = Potential Human exposure efficiency relative to U235; ETP-fw = Potential comparative Toxic Unit for ecosystems; HTP-c = Potential comparative Toxic Unit for humans (cancerogenic); HTP-nc = Potential comparative Toxic Unit for humans (not cancerogenic); SQP = Potential soil quality index

Disclaimer 1 – for the indicator “Potential Human exposure efficiency relative to U235”. This impact category deals mainly with the eventual impact of low dose ionizing radiation on human health of the nuclear fuel cycle. It does not consider effects due to possible nuclear accidents, occupational exposure or radioactive waste disposal in underground facilities. Potential ionizing radiation from the soil, radon and from some construction materials is also not measured by this indicator.

Disclaimer 2 – for the indicators “abiotic depletion potential for non-fossil resources”, “abiotic depletion potential for fossil resources”, “water (user) deprivation potential, deprivation-weighted water consumption”, “potential comparative toxic unit for ecosystems”, “potential comparative toxic unit for humans – cancerogenic”, “Potential comparative toxic unit for humans - not cancerogenic”, “potential soil quality index”. The results of this environmental impact indicator shall be used with care as the uncertainties on these results are high as there is limited experience with the indicator.

## 6. LCA: Interpretation

The use of internal recycled material in CLIMAFLEX® naturefoam exzentro reduces the need for raw materials and avoids wasting resources. CLIMAFLEX® naturefoam exzentro has a very low density, which means that little raw material is needed for high insulation efficiency, which results in significant energy savings. In addition, CLIMAFLEX® naturefoam exzentro is largely made of low-density polyethylene, so it is fully recyclable and can be recycled when it reaches the end of its life. As there is a variation in density between the different references of the CLIMAFLEX® naturefoam exzentro range, a sensitivity analysis has been performed. The results of the LCA are given for 1m<sup>3</sup> of product calculated with an average weighted foam density of 34,4 kg/m<sup>3</sup>. For the lowest density, the impacts are lowered by 12,4 % and for the highest density the impacts should be majored by 10,9 %. Most references are very close to the average density, but all impact factors can be recalculated based on the product's density. When we analyse the complete life cycle, we see that the most impacting part for all environmental impact factors is the production module and more particularly the raw materials part. With regard to global warming for the complete life cycle, more than 94% comes from the production module 1,6% from transport to the places of installation and 3,9% comes from the end of life. A more in-depth analysis of the production module A1 to A3 shows that the production of raw materials and their transport account for almost 95% of the impact Global Warming Potential. As the CLIMAFLEX® naturefoam exzentro is fully recyclable; the choice for the end of

life was that of 100% recycling. This avoids the use of new raw materials and or the exploitation of renewable or non-renewable resources. The end of life in 100% landfill has a slight impact, especially from the point of view of climate change. However, the 100% incineration scenario has the greatest impact because during incineration there is a significant release of carbon dioxide. The insulation with CLIMAFLEX® naturefoam exzentro of the sanitary and heating piping contributes to a significant reduction of CO<sub>2</sub> emissions from the heating or cooling equipment, this is not considered in this LCA. It should, however, be taken into account in the calculation of environmental impacts of the complete heating and cooling systems or of the complete building. Software that can be accessed via the following link <http://cit.nmcinsulation.eu> gives the possibility to calculate the heat flow of insulated pipe in real use conditions. One way to continue to reduce the environmental impact of the CLIMAFLEX® naturefoam exzentro would be to continue to diversify our energy sources by switching more and more to renewable energies. To this end, after having greatly increased the number of photovoltaic panels, NMC will acquire a cogeneration system. Looking for more eco-responsible suppliers must also be put in place, as well as finding raw materials manufactured locally to avoid long-distance transport as much as possible. An analysis of the plant's carbon footprint, which is currently being carried out, should enable NMC to identify areas for improvement and find solutions to achieve the goal of zero carbon.

## 7. Requisite evidence

### 7.1. VOC emissions

Eurofins Product Testing A/S has tested a wide range and variety of typical PEF (Polyethylene foam) products marketed in the EU from CEFEP (European Group of PEF/FEF manufacturers) Based on the

loading factor 0.05m<sup>2</sup>/m<sup>3</sup> (determined after consideration of the real-life applications of PEF products (in living rooms) and recommendations by the experts of the test institute) all results were found to be clearly below the limit values. For all samples below

100mg/m<sup>3</sup> TVOC after 28 days. Certificates are available on request.

## 7.2 Leaching

## 8. References

### EN 1602

EN 1602: 2013: Thermal insulating products for building applications - Determination of the apparent density

**EN ISO 8497** EN ISO 8497: Thermal insulation - Determination of steady-state thermal transmission properties of thermal insulation for circular pipes

### ISO 9001

ISO 9001: 2015: Quality management systems.

### EN13472

EN 13472: Thermal insulating products for building equipment and industrial installations - Determination of short term water absorption by partial immersion of preformed pipe insulation

### EN 13468

EN 13468: Thermal insulating products for building equipment and industrial installations - Determination of trace quantities of water-soluble chloride, fluoride, silicate, and sodium ions and pH

### EN 13501-1

EN 13501-1:2007+A1: 2013 Fire classification of construction products and building elements - Classification using test data from reaction to fire tests

### ISO 14001

ISO 14001: 2015 Environmental management systems.

### EN ISO 14025

EN ISO 14025: 2011-10: Environmental labels and declarations — Type III environmental declarations — Principles and procedures

### ISO 14040

ISO 14040: Environmental management — Life cycle assessment — Principles and framework

### ISO 14044

ISO 14044: Environmental management — Life cycle assessment — Requirements and guidelines

### EN 14707

EN 14707: 2012: Thermal insulating products for building equipment and industrial installations. Determination of maximum service temperature for preformed pipe insulation

### EN 15804

EN 15804: 2012-04 + A1 2014: Sustainability of construction works — Environmental Product Declarations — Core rules for the product category of construction products

### CEN/TR 15941

CEN/TR 15941: Sustainability of construction works - Environmental product declarations - Methodology for selection and use of generic data

According to EN 13468 the content of water-soluble chloride ions for CLIMAFLEX® naturefoam stabil is <20mg/kg

### CEN TS 16516

CEN TS 16516: AgBB, ISO 16000-3, /ISO 16000-6, /ISO16000-9/, /ISO 16000-11/ Construction products - Assessment of release of dangerous substances. Determination of emissions into indoor air

### EN 16783: 2017

EN 16783: 2017 Thermal insulation products - Product category rules (PCR) for factory made and in-situ formed products for preparing environmental product declarations.

### Candidate List Substances of Very High Concern

SVCH: date: 08.07.2021) exceeding 0.1 percentage by mass

### CEFEP

CEFEP: European group of PEF and FEF manufacturers

### Eurostat

European Statistics: Recovery rates for packaging waste Paper and cardboard packaging for the European Union 27 countries 2014  
<http://ec.europa.eu/eurostat/home>

### Eurofins

Eurofins: Eurofins Scientific is a group of international life sciences companies which provide a unique range of analytical testing services to clients across multiple industries, <http://www.eurofins.com>

### Gabi ts

GaBi 10 GaBi Software-System and Database for Life Cycle Engineering Copyright © 1992-2021 Sphera Solutions GmbH Version: 10.5.0.78 DB Schema 8007

### Institut Bauen und Umwelt

Institut Bauen und Umwelt e.V., Berlin(pub.): General Instructions for the EPD Programme of Institut Bauen und Umwelt e.V., Version 2.0 2021.

### Product Category Rules for Building-Related Products and Services

Institute Construction and Environment e.V. (IBU) Part A: Calculation Rules for the Life Cycle Assessment and Requirements on the Project Report Version 1.7

### PCR Guidance-Texts for Building-Related Products and Services

From the range of Environmental Product Declarations of Institute Construction and Environment e.V. (IBU) Part B: Requirements on the EPD for Insulating materials made of foam plastics Version 1.6 (Template) Version 1.2 (PCR specific)

### REACH

According the European Chemicals Regulation REACH manufacturers, importers and downstream users must register their chemicals and are responsible for their safe use.

### Sphera



**Publisher**

Institut Bauen und Umwelt e.V.  
Hegelplatz 1  
10117 Berlin  
Germany

Tel +49 (0)30 3087748- 0  
Fax +49 (0)30 3087748- 29  
Mail info@ibu-epd.com  
Web [www.ibu-epd.com](http://www.ibu-epd.com)

**Programme holder**

Institut Bauen und Umwelt e.V.  
Hegelplatz 1  
10117 Berlin  
Germany

Tel +49 (0)30 - 3087748- 0  
Fax +49 (0)30 - 3087748 - 29  
Mail info@ibu-epd.com  
Web [www.ibu-epd.com](http://www.ibu-epd.com)

**Author of the Life Cycle**

**Assessment**  
NMC S.A.  
Gert Noël Strasse 1  
4731 Eynatten  
Belgium

Tel +3287858500  
Fax +3287858511  
Mail robert.christiaans@nmc.be  
Web [www.nmc-insulation.com](http://www.nmc-insulation.com)



TECHNICAL  
INSULATION

**Owner of the Declaration**

NMC S.A.  
Gerd-Noël-Strasse 1  
4731 Eynatten  
Belgium

Tel +32 (0) 87 85 85 00  
Fax +32 (0) 87 85 85 11  
Mail info@nmc.eu  
Web <https://nmc-insulation.com/>